



ଝାରସୁଗୁଡ଼ା ପୌରପାଳିକା କାର୍ଯ୍ୟାଳୟ
Jharsuguda Municipality



ମଙ୍ଗଳବଜାର, ଝାରସୁଗୁଡ଼ା- ୭୬୮୨୦୧

Mangal Bazaar, Jharsuguda-768201

Mail: jsgmunicipality@yahoo.com, Ph: 06645-272236

No. 1095

Date: 25/02/2026

Sealed Quotations are invited from authorized dealer/ agencies/ suppliers/ manufactures for supply of Fibre Glass Acoustical Suspended Ceiling, Floor carpet 5.5mm thick, Providing and fixing Roller blinds of Approved make/Colour, Acoustical Wall Panel for Jharsuguda Municipality.

The rate should be quoted against the item excluding taxes. The quotationer are required to enclose their GST Registration Certificate, PAN Card, Warranty/ Guarantee details. The quotationer shall be required to produce the original copy of the required document before the undersigned at the time of opening of quotation for verification.

The quotationer should submit EMD in shape of Money Receipt/ D.D. / TDR pledge in favour of Executive Officer, Jharsuguda Municipality. The quotation paper will be available at the Cash Section from date 26.02.2026 at 10.00 AM to 07.03.2026 at 12.00 Noon in the office hours except holidays. The quotation will be received on or before dt. 07.03.2026 at 01.00 PM on Tender Box/ Speed post/ Register post and the same will be opened on dt. 07.03.2026 at 4.00 PM in presence of the respective quotationers or their authorized representative. The details will be available in the official website of Jharsuguda Municipality, DEGM, Jharsuguda from dt. 26.02.2026 to 07.03.2026. The interested persons can download the documents from the website.

The authority reserves the right to accept, cancel or reject any or all offers without assigning any reason thereof.

TERMS AND CONDITIONS:

- 1- Rate should be quoted excluding GST.
- 2- The quotationer should have GST clearance certificate and submit the Xerox copy GST clearance.
- 3- The quality and quantity of the materials will be maintained by the engineer concern.
- 4- Payment will be made after submission of invoice in shape of account pay cheque.

Memo No. 1096 / JM, Dt. 25/02/2026.

Copy to the Deputy Director I&PR, Bhubaneswar with a request to publish the matter in **Two Odia Daily** Newspapers.

Memo No. 1097 / JM, Dt. 25/02/2026.

Copy to DEGM, Collectorate, Jharsuguda for uploading this notice in the District Website i.e. <https://jharsuguda.odisha.gov.in/>.

Memo No. 1098 / JM, Dt. 25/02/2026

Copy to office notice board for wide circulation and publicity.

Executive Officer,
Jharsuguda Municipality.

Executive Officer,
Jharsuguda Municipality.

Executive Officer,
Jharsuguda Municipality.

Executive Officer,
Jharsuguda Municipality.

Sl No	Particulars	Unit	Qty	Rate
1	<p>Fibre Glass Acoustical Suspended Ceiling Tender Specification Providing & Fixing of Fibre Glass Acoustical Suspended Ceiling System Tiles with 15mm face exposed grid. The tiles shall have smooth laminated visual with Humidity Resistance (RH) of 95%, NRC 0.85 – 0.95(Average value of Absorption Co-efficient readings taken at 250 Hz, 500 Hz, 1000 Hz and 2000 Hz) as per ASTM C423 standard, , Light Reflectance ≥88% as per ASTM E-1477, Colour Pebble White, Fire Performance of Class 0/1 as per BS 476 Part 6/7 with 20/25mm Square Triangular and 8mm drop in module size of 600 x 600mm. It shall be suitable for Green Building application, with Recycled content of 85% Tiles Size 1200x300.</p> <p>SUSPENSION: The tile shall be laid on Grid with 15 mm wide T - section flanges colour global white having roll formed double stroke rotary stitching on all T sections i.e. the Main Runner, 1200 mm & 600 mm Cross Tees with a web height of 38mm (all sections). The deflection loading of the system shall be 12.5 kg/m² (as per standard installation layout mentioned below) and main beam tested as per ASTM C635 (Deflection limit less than L/360) with a deflection loading of 15kg/m. The end details of the cross tee shall be made of pre hardened steel and fixed to the ends of the cross tee to provide double locking between "cross tee to cross tee" and "cross tee to main beam". All main beam to main beam and cross tee to cross tee connection shall have a pull-out strength of more than 100kg. The T Sections shall be made of hot dipped galvanized steel of 90 gsm as per IS 277 (2003) and pre-painted steel with baked polyester paint with OT bending capability. All border cross tee/main beam shall be levelled using perimeter fill.</p> <p>INSTALLATION: To comprise main runner spaced at 1200mm securely fixed to the structural soffit using Knauf suspension system (specifications above) at 1200mm maximum. The First/Last suspension system at the end of each main runner shall not be greater than 450mm from the adjacent wall along with the first and the last main beam shall be at less than 600mm from the wall. Flush fitting 1200mm long cross tees to be interlocked between main runners at 600mm to form 1200 x 600 mm module. Cut cross tees longer than 600mm require independent support. 600 x 600mm module to be formed by fitting 600mm long flush fitting cross tees centrally between the 1200 mm cross tees. Perimeter trim to be Knauf wall angles of size 3000x19x19mm, secured to walls using screws at 450mm centre to centre maximum. Providing and Fixing of Fiber Glass Acoustical Suspended Ceiling All applicable taxes shall be charged extra, speractual i.e. 18% GST on total work order value.</p>	Sqm	177.48	
2	<p>Floor carpet 5.5mm thick Tender Specification Providing fixing carpet 5.5mm thick piles height carpet construction of level loop plain yarn type 100% strudon BCF Polypropylene and Dye Method is Solution DYED ,Machine Gauge 1/10th, Tufted piles height-4.5mm ,Tufted oil Weight 20 Oz per sq.mt Total Weight 1310 gms/m² and Primary backing - Woven Polypropylene ,Secondary Backing -Action ,Roll width 4 mtr Length 30.0 Heavy Duty Manufacturing By Advance Garman Technology Markted by SIs Enterprisers use of floor adhesive stick 7 on the floor and apply above 2mm foam use adhesive stick-7 on foam and applying carpet on top of foam and total thick 7.5mm Providing and fixing of carpet 5.5mm thick Allapplicabetaxesshallbechargedextra,asperactuali.e.18%GSTontotalworkorder value.</p>	Sqm	177.48	

3	Providing and fixing Roller blinds of Approved make/Colour. Rate shall be inclusive of necessary scotch guard treatment on both side. The overlaps should be uniform and adequate.	Sqm	49.14	
4	<p>Acoustical Wall Panel Tender Specification</p> <p>Providing and Fixing of Acoustical Wall Panel with square edges made of fiber glass substrate 25mm thick, wrapped on the front side with an acoustically transparent fabric as per the approved shade (Husk, Copper, Sangria, Sesame, Coffee, Charcoal, Titanium, Flame, Peanut and Shell). The panel shall be classified for Fire Class A, as per ASTM E-84. The Acoustical Wall Panel shall be of sizes 600x600mm (Nominal) or 600x1200mm (Nominal) and shall achieve an NRC of 0.85 (Average value of Absorption Co-efficient readings taken at 250 Hz, 500 Hz, 1000 Hz and 2000 Hz) with 50mm air gap as per ASTM C423 to be fixed to wall on a framework of wooden battens and using Wall panel Impellers (supplied by the manufacturer) or by using construction adhesives (as per the instructions laid down by the manufacturer). The fiber glass substrate shall have a recycle content of 85%.</p> <p>Installation An appropriate vapor barrier (by others) shall be applied/installed on the vertical surface before the installation to properly seal against entry of any moisture. Vapour barrier (by others) shall be installed as per Manufacturer's recommendation. Install wooden batten grid (provided by others) of section 50x50mm or as approved by the Architect on the solid wall/partition to provide level and plumb surface. The Impellers shall be fixed to the battens using self-tapping screws, 3 nos. in case of 600x600mm and 4 nos. in case of 600x1200mm. Silica based construction adhesive (by others) to be dabbed on to the projecting elements (spikes) of the Impellers. Wall Panels shall be pierced through the spikes of the Impellers ensuring the line and level of the panels are maintained.</p> <p>Providing and Fixing of Acoustical Wall Panel All applicable taxes shall be charged extra, as per actual i.e.18% GST on total work order value.</p>	Sqm	60.66	


 Executive Officer,
 Jharsuguda Municipality.